



Tom Barrett  
Mayor

Bevan K. Baker, FACHE  
Commissioner of Health

Joe'Mar Hooper, MPA  
Health Operations Administrator

www.milwaukee.gov/health

Frank P. Zeidler Municipal Building, 841 North Broadway, 3rd Floor, Milwaukee, WI 53202-3653 phone (414) 286-3521 fax (414) 286-5990

## Routine Food

ALDI, INC WISCONSIN  
ALDI INC. (STORE #16)  
8080 W BROWN DEER RD  
MILWAUKEE, WI

3/5/2014

The following list of violations of the Wisconsin Administrative Code as adopted by reference in the Milwaukee Code of Ordinances Chapter 68, and/or other City ordinance(s) must be corrected as soon as possible but not later than the date specified. A re-inspection fee may be assessed if the violation is not corrected by that date. An inspection fee may be charged for any repeat violations.

### CDC Risk Code Factor Violation(s)

Code Number	Description of Violation	Correct By
CDC Risk Violation(s):	0	

### Good Retail Practice Violations(s)

Code Number	Description of Violation	Correct By
4-501.11	Repair both walk in freezer condensate units and repair them so they don't drip condensate on the food boxes and floor. Move food from under drip areas and clean ice off floor.	3/19/2014
5-202.11	Install a vacuum breaker (back flow preventer) at the mop sink and remove the split hose device.	3/19/2014

Good Practice Violation(s): 2

Total Violations: 2

### Notes:

FDL ok

On 3/5/2014, I served these orders upon ALDI, INC WISCONSIN by leaving this report with

Inspector Signature (Inspector ID:84)

Est. # 9671

Operator Signature